

BUENA REGIONAL SCHOOL DISTRICT

Mailing Address: PO Box 309, Buena, NJ 08310
Administrative Office: 914 Main Avenue, Richland, NJ 08350
Phone (856) 697-0800 Fax (856) 697-4963
www.buenaschools.org
Honoring Tradition. Inspiring Futures.

DAVID C. CAPPUCCIO, JR.
Superintendent

Jaimi Molinelli-Bragg
Director of Curriculum & Instruction

Donna L. Phillips
Business Admin./Board Secretary

Thursday, February 6, 2025

Dear Parents, Students, and Staff of the Milanesi School Community:

The Buena Regional School District is highly committed to the safety of our students and staff. In compliance with New Jersey Department of Education regulations, lead in water testing for the Milanesi Elementary School drinking water locations was performed in January 2025. The purpose of the sampling was to identify and address any drinking water location above the EPA action level of 15 micrograms per Liter ($\mu\text{g/L}$). A drinking water location is an outlet that is designed or expected to be used for water consumption. These included, but were not limited to, classroom water fountains and sinks, water coolers, sinks in nurse's offices, faculty break rooms, and locations in kitchens used for food preparation. Bathroom, custodial, art room, and science room sinks were not sampled, as these are not expected, nor designed to be used for water consumption.

Water was allowed to stay motionless in each facility for a minimum of eight hours prior to sampling. After this time of inactivity, an "initial draw" sample was collected from the first water to come out of the outlet.

A summary of each location above the action level, as well as the short-term response to remedy the situation, is found in the chart below:

Milanesi Elementary School

SAMPLE LOCATION	FIRST DRAW RESULT	SHORT TERM RESPONSE
Bubbler – Room 105	22.7 $\mu\text{g/L}$	Taken out of service
Bubbler – Room 109	17.8 $\mu\text{g/L}$	Taken out of service
Bubbler – Room 114	37.6 $\mu\text{g/L}$	Taken out of service
Bubbler – Room 116	32.5 $\mu\text{g/L}$	Taken out of service
Bubbler – Room 127	15.1 $\mu\text{g/L}$	Taken out of service

If you have any questions, please feel free to contact the Board of Education Office.

Sincerely,



David C. Cappuccio, Jr.
Superintendent of Schools

c: File